NOTICE OF PRODUCT CERTIFICATION

CERTIFICATION NO:	**NI014340**
DATE:	**01/28/2019**
CERTIFICATION PROGRAM:	**Fire**
COMPANY:	**Treasure Valley**
CODE:	**2517-1**
EXPIRATION DATE:	**01/31/2023**

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Treasure Valley Door & Trim, LLC **1150 West Taylor Avenue** **Meridian, ID 83642**	**Lynden 20 Minute L20 MDF-R** **Fire Door Assembly** Manufacturer Specific Fire Doors for Single Swing Installation in 20 Minute Locations 1/2" Minimum Latch Throw Single Swing Only **Maximum Size: 3'0" x 7'0"** **Minimum Thickness: 1-3/4"**

SPECIFICATION	PRODUCT RATING
NFPA 252 (2008)(2012) **UL 10C (2001)(2009)** **UL 10B (2008)(2009)** **UBC Standard 7-2 (1997)** **CAN/ULC S104 (2010)**	**20 Minute-Positive Pressure With Hose Stream** **Category B Door-Additional Edge Seal Required** (unless specified in individual manufacturer's listing) **For Use in ANSI-A155/UL-63 Steel Frame** (or may also be installed in Category C-Proprietary in accordance with individual manufacturer's listing)

TEST REPORT
Intertek Test Report No: 101318303COQ-002/101503991COQ-001

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122