NOTICE OF PRODUCT CERTIFICATION

CERTIFICATION NO:	**NI012496.01-R1**
DATE:	**01/29/2015**
CERTIFICATION PROGRAM:	**Structural**
COMPANY:	**Abritek**
CODE:	**1629-1**
REVISION DATE:	**04/29/2019**

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Abritek Windows and Doors **5195 127E Rue** **Saint-Georges de Beauce, QC G5Y 5B9**	**Series "Royal" Opaque Steel** **In-Swing Side Hinged Door** Configuration: X Frame: W-959mm(37.75") H-2102mm(82.75") Panel: W-908mm(35.75") H-2007mm(79.00")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11 **AAMA/WDMA/CSA 101/I.S.2/A440-08** **CSA A440S1-09**	**Class LC-PG50 959 x 2102 (38 x 83)-SHD** **Design Pressure: 2400 Pa (50 psf)** **Negative Design Pressure: 2400 Pa (50 psf)** **Water Penetration Resistance Test Pressure: 540 Pa (11.28 psf)** **Canadian Air Infiltration/Exfiltration Level: A3**

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-310-4000
Expiration Date: **September 31, 2022**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122