

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI012798-R2  
DATE: 08/12/2015  
CERTIFICATION PROGRAM: Fire  
COMPANY: Can-Save  
CODE: 1347-1  
REVISION DATE: 06/18/2019  
EXPIRATION DATE: 08/31/2024

To verify that the "Notice of Product Certification" is valid, please visit [www.NAMICertification.com](http://www.NAMICertification.com) to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Can-Save</b> <b>411 Bayview Avenue</b> <b>Barrie, ON L4N 8Y2</b>	<b>"Novatech N300/N325/N600" Steel</b> <b>20 Minute Neutral Pressure Fire Door</b> <b>Assembly w/ Hose Stream</b>  Manufacturer Specific Fire Doors for Single Swing Installation in 20 Minute Locations  1/2" Minimum Latch Throw Single Swing Only  <b>Maximum Size: 3'0" x 6'8"</b> <b>Minimum Thickness: 1-3/4"</b>

SPECIFICATION	PRODUCT RATING
<b>CAN/ULC S104 (2010)</b> <b>UL 10B (2001)</b>	<b>20 Minute-Neutral Pressure</b> <b>With Hose Stream</b>

TEST REPORT
<b>Intertek Test Report No: 3071182-01</b>

Administrator's Signature: \_\_\_\_\_

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Fax: (804) 684-5122