

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI013721-R2
DATE: 05/23/2017
CERTIFICATION PROGRAM: Structural
COMPANY: Henselstone
CODE: 755-1
REVISION DATE: 06/26/2019

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Henselstone Window & Door Systems 113 Henselstone Lane Amissville, VA 20106	Series "Wood Segmented" Glazed Wood Side Hinged Door Configuration: OXXX Glazing: IG-3/16" Heat Strengthened Glass/ Laminate-3/16" Heat Strengthened Glass/0.090" Kuraray SGP Interlayer/3/16" Heat Strengthened Glass Frame: W-5251mm(206.75") H-3048mm(120") Panel: W-1238mm(48.75") H-2989mm(117.69") DLO: W-1073mm(42.25") H-2759mm(108.63")

SPECIFICATION	PRODUCT RATING
TAS 201/202/203-94	Design Pressure: ±3112 Pa (65 psf) Large Missile Impact Rated Water Penetration Resistance Test Pressure: 467 Pa (9.75 psf)

Product Tested By: Architectural Testing, Inc.
Report No: B9271.01-550-18
Expiration Date: May 31, 2025

Administrator's Signature:  _____

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Fax: (804) 684-5122