

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI014504.01-R1
DATE: 09/18/2019
CERTIFICATION PROGRAM: Structural
COMPANY: ASSA ABLOY
CODE: 668-1
REVISION DATE: 09/20/2019

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
ASSA ABLOY Entrance Systems US, Inc. 1900 Airport Road Monroe, NC 28110	"Full Breakout Single Slide Door System" Non-Impact Single Slide Door System (Panic Exit Device) Configuration: SO/SX Glazing: Monolithic-1/4" Tempered Glass Frame: W-2743mm(108") H-2642mm(104") Panel: W-1390mm(54.75") H-2374mm(93.5") DLO: W-1114mm(43.88") H-2085mm(82.12")

SPECIFICATION	PRODUCT RATING
TAS 202*-94 ASTM F842	Design Pressure: +80/-80 psf Forced Entry Resistance: Passed/Grade 25

*No Water Penetration Test Performed

Product Tested By: Intertek-Georgia
Report No: J5785.10-550-18/J5787.09-550-18
Expiration Date: **June 30, 2023**

Administrator's Signature: _____ 

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122