

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI012833-R1  
DATE: 09/09/2015  
CERTIFICATION PROGRAM: Fire  
COMPANY: Lumbermen  
CODE: 1021-1  
EXPIRATION DATE: 09/30/2024

To verify that the "Notice of Product Certification" is valid, please visit [www.NAMICertification.com](http://www.NAMICertification.com) to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Lumbermen's Incorporated</b> <b>3810 Roger B. Chaffee Drive, SE</b> <b>Grand Rapids, MI 49548</b>	<b>90 Minute Single Swing</b> <b>Foam Filled Simulated Panel or</b> <b>Flush Steel Door Assemblies</b>  Configuration: X 22 or 24 Gauge Steel Skin Door w/Foam Filled Core for Single Swing Installation in 90 Minute Locations  <b>Maximum Size: 3'6" x 7'0"</b>  <b>Minimum Thickness: 1-3/4"</b>

SPECIFICATION	PRODUCT RATING
<b>NFPA 252 (1999)</b> <b>UL 10C (1998)</b> <b>UBC Standard 7-2 (1997)</b> <b>CAN4-S104 (ULC-S104)</b>	<b>90 Minute-Without Hose Stream</b> <b>Positive Pressure</b> <b>Category B-Requires Additional</b> <b>Listed Edge Seal</b> <b>For Use in Category C Standard Frame</b> (or may also be installed in Category C - Proprietary, in accordance with individual manufacturer's listing)
TEST REPORT	EVALUATION REPORT
<b>Intertek Test Report No:</b> <b>3124893MID-001</b>	<b>Intertek EEV 3074357</b> <b>Intertek EEV 3164061MID-002</b>

Administrator's Signature: \_\_\_\_\_

A handwritten signature in black ink, appearing to be "M.D.", is written over the signature line.

**NATIONAL ACCREDITATION AND  
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124/ Fax: (804) 684-5122