

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI012046.01-R2  
DATE: 07/08/2014  
CERTIFICATION PROGRAM: Structural  
COMPANY: Wincore  
CODE: 1640-1  
REVISION DATE: 01/15/2020

To verify that the "Notice of Product Certification" is valid, please visit [www.NAMICertification.com](http://www.NAMICertification.com) to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Wincore Window Company, LLC</b> <b>250 Staunton Turnpike</b> <b>Parkersburg, WV 26104</b>	<b>Series "400/500/5400/5400S" Vinyl</b> <b>Double Hung Window w/Transom &amp;</b> <b>Two-Piece Zero Mullion</b> <b>Replacement Frame</b>  Configuration: O//X/X Glazing: Insulating Glass (Annealed) Frame: W-1219mm(48.00") H-2819mm(111.00") Transom: W-1219mm(48.00") H-1219mm(48.00") Sash: W-1162mm(45.75") H-800mm(31.50") DLO: W-1121mm(44.12") H-1121mm(44.12")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-17</b> <b>AAMA/WDMA/CSA 101/I.S.2/A440-11</b> <b>AAMA/WDMA/CSA 101/I.S.2/A440-08</b>	<b>Class R-PG40 1219 x 2819 (48 x 111)-H</b> <b>Design Pressure: 1920 Pa (40 psf)</b> <b>Negative Design Pressure: 1920 Pa (40 psf)</b> <b>Water Penetration Resistance Test Pressure: 290 Pa (6.06 psf)</b>

Product Tested By: Architectural Testing, Inc.  
Report No: D7352.01-501-47/W-1920  
Expiration Date: April 30, 2026

Administrator's Signature: \_\_\_\_\_

A handwritten signature in black ink, appearing to be 'Shi' or similar, written over a horizontal line.

**NATIONAL ACCREDITATION AND  
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
Fax: (804) 684-5122