

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI012046-R2  
**DATE:** 07/08/2014  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** Wincore  
**CODE:** 1640-1  
**REVISION DATE:** 01/15/2020

To verify that the "Notice of Product Certification" is valid, please visit [www.NAMICertification.com](http://www.NAMICertification.com) to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Wincore Window Company, LLC</b>  <b>250 Staunton Turnpike</b>  <b>Parkersburg, WV 26104</b>	<p style="text-align: center;"><b>Series "400/500/5400/5400S" Vinyl Double Hung Window w/Transom &amp; Two-Piece Zero Mullion New Construction Frame</b></p> <p style="text-align: center;">Configuration: O//X/X Glazing: Insulating Glass (Annealed)</p> <p>Frame: W-1219mm(48.00") H-2819mm(111.00")                      Transom: W-1219mm(48.00") H-1219mm(48.00")                      Sash: W-1162mm(45.75") H-800mm(31.50")                      DLO: W-1121mm(44.12") H-1121mm(44.12")</p>

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17 AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08	<p style="text-align: center;"><b>Class R-PG40 1219 x 2819 (48 x 111)-H</b>  <b>Design Pressure: 1920 Pa (40 psf)</b>  <b>Negative Design Pressure: 1920 Pa (40 psf)</b>                      Water Penetration Resistance Test Pressure: 290 Pa (6.06 psf)</p>

Product Tested By: Architectural Testing, Inc.  
 Report No: D7352.01-501-47/W-1920  
 Expiration Date: **April 30, 2026**

Administrator's Signature: \_\_\_\_\_

**NATIONAL ACCREDITATION AND  
 MANAGEMENT INSTITUTE, INC.**  
 4794 George Washington Memorial Highway  
 Hayes, VA 23072  
 Tel: (804) 684-5124/ Fax: (804) 684-5122