

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI012053.01-R3  
DATE: 07/09/2014  
CERTIFICATION PROGRAM: Structural  
COMPANY: Orepac  
CODE: 1234-1  
REVISION DATE: 01/18/2020

To verify that the "Notice of Product Certification" is valid, please visit [www.NAMICertification.com](http://www.NAMICertification.com) to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>OrePac Building Products</b> <b>30160 SW Orepac Avenue</b> <b>Wilsonville, OR 97070</b>	<b>Series "CSA Opaque"</b> <b>Opaque In-Swing Fiberglass Side-Hinged</b> <b>Door w/Glazed Sidelites</b>  Configuration: OXO Glazing: Insulating Glass (Tempered)  Frame: W-1740mm(68.50") H-2073mm(81.62") Panel: W-910mm(35.93") H-2008mm(79.06") Sidelite: W-356mm(14.00") H-2013mm(79.25") DLO: W-151mm(5.63") H-1599mm(62.93")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-11</b> <b>AAMA/WDMA/CSA 101/I.S.2/A440-08</b> <b>CSA A440S1-09</b>	<b>Class R PG45 1740 x 2073 (69 x 82)-LW SHD</b> <b>Design Pressure: 2160 Pa (45 psf)</b> <b>Negative Design Pressure: 2160 Pa (45 psf)</b> Water Penetration Resistance Test Pressure: 260 Pa(5.43 psf) Canadian Air Infiltration/Exfiltration Level: A3

Product Tested By: Architectural Testing Incorporated  
Report No: D6426.03-501-47  
Expiration Date: March 31, 2022

Administrator's Signature: \_\_\_\_\_

**NATIONAL ACCREDITATION AND  
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
Fax: (804) 684-5122