

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI012112.12-R2  
**DATE:** 09/04/2014  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** Wincore  
**CODE:** 1640-1  
**REVISION DATE:** 01/14/2020

To verify that the "Notice of Product Certification" is valid, please visit [www.NAMICertification.com](http://www.NAMICertification.com) to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Wincore Window Company, LLC</b> <b>250 Staunton Turnpike</b> <b>Parkersburg, VA 26104</b>	<b>Series "5400/5400S"</b> <b>Vinyl Double Hung Window</b>  Configuration: X/X Glazing: Insulated Glass (Annealed)  Frame: W-1117mm(44.00") H-1320mm(52.00") DLO: W-972mm(38.30") H-568mm(22.40")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-17</b> <b>AAMA/WDMA/CSA 101/I.S.2/A440-11</b> <b>AAMA/WDMA/CSA 101/I.S.2/A440-08</b>	<b>Class LC-PG45 1117 x 1320 (44 x 52)-H</b> <b>Design Pressure: 2154 Pa (45 psf)</b> <b>Negative Design Pressure: 2154 Pa (45 psf)</b> <b>Water Penetration Resistance Test Pressure: 359 Pa (7.50 psf)</b>

Product Tested By: Testing Evaluation Laboratory  
Report No: TEL 02801066/TEL 02801067/W-1716 /W-1920  
Expiration Date: **July 31, 2026**

Administrator's Signature: 

**NATIONAL ACCREDITATION AND  
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
Fax: (804) 684-5122