

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI013094-R2  
DATE: 03/31/2016  
CERTIFICATION PROGRAM: Structural  
COMPANY: Dunbarton  
CODE: 1319-1  
REVISION DATE: 02/03/2020

To verify that the "Notice of Product Certification" is valid, please visit [www.NAMICertification.com](http://www.NAMICertification.com) to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Dunbarton Corporation</b> <b>555 Benton Industrial Road</b> <b>Camden, TN 38320</b>	<b>"Gladiator/Finishield"</b> <b>25 Gauge Thin Stile &amp; Rail</b> <b>Inswing Glazed Steel Door</b>  Configuration: X  Frame: W-948mm(37.32") H-2085mm(82.09") Panel: W-908mm(35.75") H-2013mm(79.25") DLO: W-537mm(21.14") H-1607mm(63.27")

SPECIFICATION	PRODUCT RATING
<b>AAMA 1702.2-95/02/12</b> <b>Federal Manufactured Home Construction</b> <b>&amp; Safety Standard 3280.305</b> (applicable sections)	<b>Manufactured Housing-Passed</b> <b>Wind Zone III</b> <b>Design Wind Pressure Rating:</b> <b>+58/-58 psf</b>

Product Tested By: National Certified Testing Laboratories  
Report No: SJW2014-021  
Expiration Date: January 31, 2021

Administrator's Signature: \_\_\_\_\_

A handwritten signature in black ink, appearing to be "S. J. W.", written over a horizontal line.

**NATIONAL ACCREDITATION AND  
MANAGEMENT INSTITUTE, INC.**  
4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
Fax: (804) 684-5122