NOTICE OF PRODUCT CERTIFICATION

CERTIFICATION NO:	**NI013095-R2**
DATE:	**03/31/2016**
CERTIFICATION PROGRAM:	**Structural**
COMPANY:	**Dunbarton**
CODE:	**1319-1**
REVISION DATE:	**02/03/2020**

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Dunbarton Corporation **555 Benton Industrial Road** **Camden, TN 38320**	**"Gladiator/Finishield"** **25 Gauge Thin Stile & Rail** **Outswing Glazed Steel Door** Configuration: X Frame: W-952mm(37.48") H-2051mm(80.74") Panel: W-909mm(35.79") H-2012mm(79.21") DLO: W-537mm(21.14") H-1602mm(63.07")

SPECIFICATION	PRODUCT RATING
AAMA 1702.2-95/02/12 **Federal Manufactured Home Construction** **& Safety Standard 3280.305** **(applicable sections)**	**Manufactured Housing-Passed** **Wind Zone III** **Design Wind Pressure Rating:** **+58/-58 psf**

Product Tested By: National Certified Testing Laboratories
Report No: SJW2014-025
Expiration Date: **January 31, 2021**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122