

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI014619.01  
**DATE:** 01/11/2020  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** Prime Window  
**CODE:** 2288-1

To verify that the "Notice of Product Certification" is valid, please visit [www.NAMICertification.com](http://www.NAMICertification.com) to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Prime Window Systems</b> <b>3400 Tacoma Street</b> <b>Union Gap, WA 98903</b>	<b>Series "7000"</b> <b>Vinyl Casement over Fixed Window</b>  Configuration: X/O Glazing: Exterior-Insulating Glass (Annealed) Interior-Monolithic (Annealed)  Frame: W-914mm(36") H-2286mm(90") Vent: W-829mm(32.63") H-1448mm(57")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-17</b>	<b>Class CW-PG60 914 x 2286 (36 x 90)-C-FW</b> <b>Design Pressure: ±2800 Pa (±60 psf)</b> <b>Canadian Air Infiltration/Exfiltration Level: A3</b> <b>Water Penetration Resistance Test Pressure: 720 Pa (15.04 psf)</b>

Product Tested By: Intertek (WA)  
Report No: K1948.01-901-44-R1/K1966.001-901-44 R1/C9853.02-801-47  
Expiration Date: **September 30, 2023**

Administrator's Signature: \_\_\_\_\_

A handwritten signature in black ink, appearing to be 'S.M.', written over a horizontal line.

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
Fax: (804) 684-5122