

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI014623  
DATE: 01/13/2019  
CERTIFICATION PROGRAM: Structural  
COMPANY: Prime Window  
CODE: 2288-1

To verify that the "Notice of Product Certification" is valid, please visit [www.NAMICertification.com](http://www.NAMICertification.com) to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Prime Window Systems</b> <b>3400 Tacoma Street</b> <b>Union Gap, WA 98903</b>	<b>Series "1000"</b> <b>Vinyl Tilt/Turn Dual Action Window</b> <b>Next To Fixed Window</b>  Configuration: XO Glazing: Insulating Glass (Annealed)  Frame: W-1816mm(71.5") H-2426mm(95.5") Vent: W-1060mm(41.75") H-1772mm(69.75")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-17</b>	<b>Class LC-PG50 1816 x 2426 (72 x 96)-</b> <b>DAW-FW</b> <b>Design Pressure: ±2400 Pa (±50 psf)</b> Water Penetration Resistance Test Pressure: 440 Pa (9.20 psf) Canadian Air Infiltration/Exfiltration Level: A3

Product Tested By: Architectural Testing, Inc.  
Report No: J8111.01-901-44/G0275.01-901-44/C7401.02-901-44  
Expiration Date: **June 30, 2023**

Administrator's Signature: \_\_\_\_\_

**NATIONAL ACCREDITATION AND  
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Fax: (804) 684-5122