

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI014079.03-R1  
**DATE:** 05/29/2018  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** Acadia  
**CODE:** 317-1  
**REVISION DATE:** 02/27/2020

To verify that the "Notice of Product Certification" is valid, please visit [www.NAMICertification.com](http://www.NAMICertification.com) to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Acadia Windows &amp; Doors</b> <b>930 Todds Lane</b> <b>Rosedale, MD 21237</b>	<b>Series "800"</b> <b>Vinyl Tilt Double Hung Window</b>  Configuration: X/X Glazing: Insulating Glass (Tempered)  Frame: W-1118mm(44") H-1905mm (75") Sashl: W-1054mm(41.5") H-946mm(37.25")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-11</b>	<b>Class LC-PG40 1118 x 1905 (44 x 75)-H</b> <b>Design Pressure: ±1920 Pa (40 psf)</b> Water Penetration Resistance Test Pressure: 360 Pa (7.52 psf)

Product Tested By: National Certified Testing Laboratories  
Report No: NCTL-110-20954-4/NCTL-110-20954-1  
Expiration Date: March 31, 2032

Administrator's Signature: \_\_\_\_\_

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
Fax: (804) 684-5122