

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI014079.04-R1
DATE: 05/29/2018
CERTIFICATION PROGRAM: Structural
COMPANY: Acadia
CODE: 317-1
REVISION DATE: 02/27/2020

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Acadia Windows & Doors 930 Todds Lane Rosedale, MD 21237	Series "800" Vinyl Tilt Double Hung Window Configuration: X/X Glazing: Insulating Glass (Tempered) Frame: W-1016mm(40") H-1600mm (63") Sash: W-953mm(37.5") H-791mm(31.12")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11	Class R-PG50 1016 x 1600 (40 x 63)-H Design Pressure: +2400 Pa (50 psf) Negative Design Pressure: -2640 Pa (55 psf) Water Penetration Resistance Test Pressure: 360 Pa (7.52 psf)

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-110-20954-5/NCTL-110-20954-1
Expiration Date: **March 31, 2032**

Administrator's Signature: _____


NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122