

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI009966.01-R1
DATE: 07/15/2009
CERTIFICATION PROGRAM: Structural
COMPANY: Henselstone
CODE: 755-1
REVISION DATE: 03/09/2020

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Henselstone Window & Door Systems 113 Henselstone Lane Amissville, VA 20106	Series "Dual Action Window/Patio Door" Impact Rated Wood Dual Action Hinged Glass Door Configuration: XX Glazing: IG-Laminate-0.106" Annealed Glass/ 0.015PVB/0.106" Annealed Glass & Laminate- 0.163" Annealed Glass/0.090"PVB/0.163" Annealed Glass Frame: W-1828mm(72") H-2590mm(102") Panel: W-886mm(34.88") H-2484mm(97.81")

SPECIFICATION	PRODUCT RATING
ASTM E1886-04/E1996-04	Design Pressure: +65/-65 psf Wind Zone 3-Missile Level D

Product Tested By: ETC Laboratories
Report No: ETC-05-950-16520.0
Expiration Date: July 31, 2024

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122