


NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI014749
DATE: 03/10/2020
CERTIFICATION PROGRAM: Fire
COMPANY: Stier Supply
CODE: 1728-1
EXPIRATION DATE: 03/31/2024

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Stier Supply Company 303 Bellinger Lane Gaston, SC 29053	Therma Tru 90 Minute Steel Single Swing Door w/Bayer Baytherm 3003 Core 22 Gauge Steel Skin Door w/Bayer Baytherm 3003 Core for single swing installation in 90 Minute locations 1/2" Minimum Latch Throw Single Swing Only Maximum Size: 3'0" x 6'8" 914mm x 2032mm

SPECIFICATION	PRODUCT RATING
NFPA 252 (2008) UL 10C (2009) CAN4 S104(1985)	90 Minute-Positive Pressure With Hose Stream Category B Door-Additional Edge Seal Required For Use in Category C Frame

TEST REPORT

Intertek Test Report No: 3193924MID-007

A handwritten signature in black ink, appearing to be "S. D.", written over a horizontal line.

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway
Hayes, VA 23072

Tel: (804) 684-5124/ Fax: (804) 684-5122