

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI012613-R1
DATE: 04/16/2015
CERTIFICATION PROGRAM: Fire
COMPANY: Benbilt
CODE: 855-1
REVISION DATE: 03/23/2020
EXPIRATION DATE: 04/30/2024

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
BenBilt Building Systems 123 Benbilt Place Greensburg, PA 15601	20 Minute Fiberglass Reinforced Faced Door w/Proprietary Core (Simulated Panel Type or Flush) Manufacture Specific Fire Door Frames for Single Swing Installation in 20 Minute Locations Single Door Maximum Size: 3'0" x 8'0" Minimum Thickness: 1-11/16"

SPECIFICATION	PRODUCT RATING
UL 10C (2009) NFPA 252 (2008) NFPA 252 (2012) CAN4 S104 (1985)	20 Minute-without Hose Stream Positive Pressure Category A- No Additional Edge Sealing Required

TEST REPORT

**Intertek Test Report No: 3033943, 3084465, 3176111MID-002,
3187023MID-002, 100354358MID-001 & 101083967MID-001**

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be 'S. D.', is written over the signature line.

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122