

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI014760
DATE: 03/23/2020
CERTIFICATION PROGRAM: Fire
COMPANY: Stier Supply
CODE: 1728-1
EXPIRATION DATE: 03/31/2024

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Stier Supply Company 303 Bellinger Lane Gaston, SC 29053	Crest Doors 20 Minute Positive Pressure Particleboard Core/Wood Veneer Side-Hinged Door Assembly Manufacturer Specific Fire Doors for Single & Double Swing Installation in 20 Minute Locations 1/2" Minimum Latch Throw Single & Double Swing Only Single Maximum Size: 4'0" x 9'0" Double Maximum Size: 8'0" x 9'0" Minimum Thickness: 1-3/4"

SPECIFICATION	PRODUCT RATING
UBC-7-2-97 UL 10C (1998)(2009) NFPA 252 (1995)(2008)	20 Minute-Positive Pressure w/o Hose Stream Category A Door-No Additional Edge Seal Required Category B Door-Additional Edge Seal Required For Use in Category C Frame <small>(or may also be installed in Category C-Proprietary in accordance with individual manufacturer's listing)</small>

TEST REPORT
Warnock Hershey Test Report No: WHI-495-1367

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be 'Shirley'.

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Fax: (804) 684-5122