

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI014768.01
DATE: 04/05/2020
CERTIFICATION PROGRAM: Structural
COMPANY: EnergyWall
CODE: 2233-1

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
EnergyWall Windows and Door 500 Victoria Road Austintown, OH 44515	Series "1180/3080" Vinyl Sliding Door Configuration: XO Glazing: Insulating Glass (Tempered) Frame: W-1803mm(71") H-2019mm(79.5") Panel: W-908mm(35.75") H-1959mm(77.13") DLO: W-781mm(30.75") H-1832mm(72.13")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08	Class R-PG30 1803 x 2019 (71 x 80)-SD Design Pressure: ±1440 Pa (30 psf) Water Penetration Resistance Test Pressure: 220 Pa (4.6 psf)

Product Tested By: Intertek
Report No: F8022.01-501-47
Expiration Date: April 31, 2024

Administrator's Signature: 

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122