

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI013465.19
DATE: 04/27/2020
CERTIFICATION PROGRAM: Structural
COMPANY: Prime Window
CODE: 2287-1

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Prime Window Systems 12775 East 38th Avenue Denver, CO 80239	Series "720" Vinyl Triple Fixed Over Casement/Fixed System Configuration: OOO/XOX Glazing: Insulating Glass (Annealed) Frame: W-2767mm(109") H-2451mm(96.5") Vent: W-870mm(34.25") H-1784mm(70.25") DLO: W-781mm(30.75") H-1692mm(66.63")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17	Class CW-PG40 2767 x 2451 (109 x 97)-C Water Penetration Resistance Test Pressure: 440 Pa (9.20 psf) Canadian Air Infiltration/Exfiltration Level: A3

Product Tested By: Intertek, PLC
Report No: K8412.01-901-44
Expiration Date: **April 30, 2024**

Administrator's Signature: _____


**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122