NOTICE OF PRODUCT CERTIFICATION

CERTIFICATION NO:	**NI014825**
DATE:	**04/23/2020**
CERTIFICATION PROGRAM:	**Fire**
COMPANY:	**Kempsville**
CODE:	**2587-1**
EXPIRATION DATE:	**04/30/2024**

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Kempsville Building Materials Corp. **3300 Business Center Drive** **Chesapeake, VA 23323**	**Crest Doors 20 Minute Positive Pressure** **Particleboard Core/Wood Veneer** **Side-Hinged Door Assembly** Manufacturer Specific Fire Doors for Single & Double Swing Installation in 20 Minute Locations 1/2" Minimum Latch Throw Single & Double Swing Only **Single Maximum Size: 4'0" x 9'0"** **Double Maximum Size: 8'0" x 9'0"** **Minimum Thickness: 1-3/4"**

SPECIFICATION	PRODUCT RATING
UBC-7-2-97 **UL 10C (1998)(2009)** **NFPA 252 (1995)(2008)**	**20 Minute-Positive Pressure w/o Hose Stream** **Category A Door-No Additional Edge Seal Required** **Category B Door-Additional Edge Seal Required** **For Use in Category C Frame** (or may also be installed in Category C-Proprietary in accordance with individual manufacturer's listing)

TEST REPORT
Warnock Hershey Test Report No: WHI-495-1367

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122