

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI014830
DATE: 04/27/2020
CERTIFICATION PROGRAM: Structural
COMPANY: Moss
CODE: 206-1

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Moss Supply Company 5001 North Graham Street Charlotte, NC 28269	Series "7300" Vinyl Sliding Glass Door (New Construction) Configuration: XO Glazing: IG-3/16" Tempered Glass/1/8: Annealed Glass/0.090" DuPont SGP Interlayer/1/8" Annealed Glass Frame: W-2438mm(96") H-2438mm(96") Panel: W-1219mm(48") H-2362mm(93") DLO: W-1022mm(40.25") H-2162mm(85.13")

SPECIFICATION	PRODUCT RATING
AAMA 506-11 ASTM E1886-05/E1996-12 AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08	Class LC-PG50 2438 x 2438 (96 x 96)-SD Design Pressure: ±2400 Pa (50 psf) Water Penetration Resistance Test Pressure: 360 Pa (7.52 psf) Canadian Air Infiltration/Exfiltration Level: A3 Wind Zone 3 - Missile Level D

Product Tested By: Intertek, PLC
Report No: F9932.05-501-44/F9932.06-501-44
Expiration Date: **April 30, 2024**

A handwritten signature in black ink, appearing to be "S. D.", written over a horizontal line.

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122