NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI011981.01-R3

DATE: 08/03/2015

CERTIFICATION PROGRAM: Structural

COMPANY: Southeast Arch

CODE: 2039-1

REVISION DATE: 05/14/2020

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Southeast Architectural Millwork, Inc.	"Wood Door with Transoms/Sidelites"
3485 Highway 411	In-Swing Wood Side-Hinged Door
White, GA 30184	w/Sidelites & Transoms
	Configuration: OOO/OXO Glazing: IG-1/8" Tempered Glass/Laminate-3/16" Heat Strengthened Glass/0.120" Allnex Uvekol Interlayer/3/16" Heat Strengthened Glass
	Frame: W-2502mm(98.5") H-3188mm(125.5") Panel: W-1064mm(41.88") H-2419mm(95.25")
	SL: W-606mm(23.88") H-2419mm(95.25") TR: W-1105mm(43.5") H-610mm(24")
	DLO: W-784mm(30.88") H-1286mm(50.63")

SPECIFICATION	PRODUCT RATING
ASTM E283-04/E330-02/E331-00 ASTM E1886-05/E1996-05 TAS 202-94 (Structural Only) TAS-201/203-94	Design Pressure: ±2400 Pa (±50 psf) Water Penetration Resistance Test Pressure: 0 Pa (0.00 psf) Wind Zone 4 - Missile Level D Large Missile Impact Rated

Product Tested By: Architectural Testing Incorporated

Report No: C7124.03-550-18-R1

Expiration Date: July 31, 2027

Administrator's Signature:

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway Hayes, VA 23072

Tel: (804) 684-5124/ Fax: (804) 684-5122