

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI011981.02-R2
DATE: 08/03 /2015
CERTIFICATION PROGRAM: Structural
COMPANY: Southeast Arch
CODE: 2039-1
REVISION DATE: 05/14/2020

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Southeast Architectural Millwork, Inc. 3485 Highway 411 White, GA 30184	Series "Wood Door with Transom" In-Swing Glazed Wood Side-Hinged Double Doors w/Transom Configuration: O/XX Glazing: IG- 3/16" Tempered Glass/Laminate-3/16" Heat Strengthened Glass/0.100" Eastman Chemical Saflex PVB Interlayer/3/16" Heat Strengthened Glass Frame: W-1886mm(74.25") H-3188mm(125.5") Panel: W-911mm (35.88") H-2413mm(95") Transom: W-1829mm(72") H-584mm(23") DLO: W-622mm(24.5") H-2057mm(81")

SPECIFICATION	PRODUCT RATING
ASTM E283-04/E330-02/E331-00 ASTM E1886-05/E1996-05 TAS 202-94 (Structural Only) TAS-201/203-94	Design Pressure: ±2400 Pa (±50 psf) Water Penetration Resistance Test Pressure: 0 Pa (0.00 psf) Wind Zone 4 - Missile Level D Large Missile Impact Rated

Product Tested By: Architectural Testing Incorporated
Report No: C7124.04-550-18-R1
Expiration Date: September 30, 2027

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be "S. D.", is written over the signature line.

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122