

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI011981-R3  
**DATE:** 05/21/2014  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** Southeast Arch  
**CODE:** 2039-1  
**REVISION DATE:** 05/14/2020

To verify that the "Notice of Product Certification" is valid, please visit [www.NAMICertification.com](http://www.NAMICertification.com) to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<p><b>Southeast Architectural Millwork, Inc.</b></p> <p><b>3485 Highway 411</b></p> <p><b>White, GA 30184</b></p>	<p style="text-align: center;"><b>Series "Wood Door with Transom"</b></p> <p style="text-align: center;"><b>Out-Swing Glazed Wood Side-Hinged</b></p> <p style="text-align: center;"><b>Double Doors w/Transom</b></p> <p style="text-align: center;">Configuration: O/XX                      Glazing: IG-3/16" Tempered Glass/Laminate-3/16" Heat Strengthened Glass/0.100" Saflex PVB Interlayer/3/16" Heat Strengthened Glass or 3/16" Tempered Glass/Laminate-3/16" Heat Strengthened Glass/0.100" Allnex Uvekoll Interlayer/3/16" Heat Strengthened Glass</p> <p>Frame: W-1886mm(74.25")      H-3162mm(124.5")</p> <p>Panel: W-911mm(35.88")      H-2438mm(96")                      Transom: W-1886mm(74.25")      H-610mm(24")</p> <p>DLO: W-632mm(24.88")      H-2070mm(81.5")</p>

SPECIFICATION	PRODUCT RATING
<p><b>TAS 202-94</b> (Structural Only) <b>TAS-201/203-94</b></p>	<p><b>Design Pressure: ±2400 Pa (±50 psf)</b>                      Water Penetration Resistance Test Pressure: 0 Pa (0.00 psf)  <b>Wind Zone 4 - Missile Level D</b>  <b>Large Missile Impact Rated</b></p>

Product Tested By: Architectural Testing Incorporated  
 Report No: C7124.01-550-18-R1  
 Expiration Date: October 31, 2027

Administrator's Signature: \_\_\_\_\_

**NATIONAL ACCREDITATION AND  
 MANAGEMENT INSTITUTE, INC.**  
 4794 George Washington Memorial Highway  
 Hayes, VA 23072  
 Tel: (804) 684-5124  
 Fax: (804) 684-5122