

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI014872
DATE: 05/25/2020
CERTIFICATION PROGRAM: Structural
COMPANY: Four Seasons
CODE: 1812-1

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Four Seasons Solar Products, LLC 5005 Veterans Memorial Highway Holbrook, NY 11741	Series "S-7500" Vinyl Sliding Door Configuration: OX Glazing: Insulating Glass (Tempered) Frame: W-2440mm(96.06") H-2440mm(96.06") Panel: W-1223mm(48.15") H-2330mm(91.73")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-08 AAMA/WDMACSA 101/I.S.2/A440-11 A440S1-09/17	Class LC-PG35 2440 x 2440 (96 x 96)-SD Design Pressure: ±1680 Pa (35 psf) Water Penetration Resistance Test Pressure: 290 Pa(6.0 psf) Canadian Air Infiltration/Exfiltration Level: A3

Product Tested By: AIR-INS inc.
Report No: AI-04159-D1 Rev. 1
Expiration Date: May 31, 2024

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be 'S. D.', written over a horizontal line.

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122