## NOTICE OF PRODUCT CERTIFICATION •



**CERTIFICATION NO: NI004894-R7** 

**DATE:** 05/15/2002

CERTIFICATION PROGRAM: Structural

COMPANY: Window Tech

**CODE:** 008-1

**REVISION DATE:** <u>07/08/2020</u>

To verify that the "Notice of Product Certification" is valid, please visit <a href="www.NAMICertification.com">www.NAMICertification.com</a> to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Window Tech Systems, Inc.	Series "6000" Horizontal
15 Stonebreak Road	Sliding Aluminum Prime Window
Malta, NY 12020	
	Configuration: XX Glazing: Insulating Glass (Annealed)
	Frame: W-1828mm(72") H-1524mm(60")
	Sash: W-914mm(36") H-1447mm(57")

SPECIFICATION	PRODUCT RATING
AAMA/NWWDA 101/I.S.2-97	HS-C50
ASTM F588-97	FER-Passed

Product Tested By: National Certified Testing Laboratories Report No: NCTL-110-8016-1(Structural/FER)

Expiration Date: August 31, 2024

Administrator's Signature:

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway Hayes, VA 23072 Tel: (804) 684-5124

Tel: (804) 684-5124 Fax: (804) 684-5122