

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI013504.06-R2
DATE: 02/12/2017
CERTIFICATION PROGRAM: Structural
COMPANY: Ply Gem
CODE: 1408-1
REVISION DATE: 07/06/2020

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Ply Gem Window Group 433 North Main Street Rocky Mount, VA 24151	Series "700" Vinyl Double Project-Out Bottom Awning Over Triple Fixed Composite Window Configuration: XOX/OOO Glazing: Insulating Glass (Annealed) Frame: W-1816mm(71.5") H-2426mm(95.5") Vent: W-576mm(22.68") H-881mm(34.69")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08 CMBSO 1-79/CAWM 301	Class LC-PG40 1816 x 2426 (72 x 96)-AP Design Pressure: ±1920 Pa (40 psf) Water Penetration Resistance Test Pressure: 290 Pa (6.06 psf)

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-310-5715/NCTL-310-5553
Expiration Date: **June 30, 2028**

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be "Shirley", written over a horizontal line.

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122