

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI013272-R1
DATE: 06/21/2016
CERTIFICATION PROGRAM: Structural
COMPANY: Milliken
CODE: 997-1
REVISION DATE: 08/04/2020

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Milliken Millwork, Inc. 6361 Sterling Drive North Sterling Heights, MI 48312	"JELD-WEN Opaque Series" In-Swing Steel Side-Hinged Door w/Steel Edge (Adjustable Sill) Configuration: X Frame: W-997mm(39.25") H-2099mm(82.62") Panel: W-908mm(35.75") H-2007mm(79")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08 CSA A440S1-09	Class R-PG40 997 x 2099 (39 x 83)-SHD Design Pressure: 1915 Pa (40 psf) Negative Design Pressure: 3120 Pa (65 psf) Water Penetration Resistance Test Pressure: 290 Pa (6.06 psf) Canadian Air Infiltration/Exfiltration Level: A2

Product Tested By: Architectural Testing, Inc.
Report No: F8396.01-251-47 (Spec 1)
Expiration Date: May 31, 2024

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122