

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI014886.07
DATE: 06/22/2020
CERTIFICATION PROGRAM: Structural
COMPANY: Reeb
CODE: 847-1

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Reeb Millwork Corporation 1000 Maloney Circle Bethlehem, PA 18015	Series "Smooth-Star Flush" Glazed Fiberglass Out-Swing Side Hinged Door Assembly (w/Sidelites & Shootbolt System) Configuration: OXXO Glazing - Insulating Glass (Tempered) Frame: W-3874mm(152.50") H-2064mm(81.25") Panel: W-914mm(36") H-2013mm(79.25") DLO: W-660mm(26") H-1600mm(63")

SPECIFICATION	PRODUCT RATING
ASTM E283-04 ASTM E330-02 ASTM E331-00	Design Pressure: +50 / -50 psf Water Penetration Resistance Test Pressure: 359 Pa (7.50 psf)

Product Tested By: Testing Evaluation Laboratories, Inc.
Report No: TEL 01461721
Expiration Date: **June 30, 2024**

Administrator's Signature: _____


**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122