

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI014886.08  
**DATE:** 06/22/2020  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** Reeb  
**CODE:** 847-1

To verify that the "Notice of Product Certification" is valid, please visit [www.NAMICertification.com](http://www.NAMICertification.com) to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Reeb Millwork Corporation</b> <b>1000 Maloney Circle</b> <b>Bethlehem, PA 18015</b>	<b>Series "Smooth-Star Flush"</b> <b>Glazed Fiberglass In-Swing Side Hinged</b> <b>Door Assembly</b> <b>(w/Sidelites)</b>  Configuration: OXXO Glazing - Insulating Glass (Tempered) Frame: W-2680mm(105.50") H-2083mm(82") Panel: W-914mm(36") H-2013mm(79.25") DLO: W-660mm(26") H-1600mm(63")

SPECIFICATION	PRODUCT RATING
<b>ASTM E283-04</b> <b>ASTM E330-02</b> <b>ASTM E331-00</b>	<b>Design Pressure: +50 / -50 psf</b> Water Penetration Resistance Test Pressure: 0 Pa (0.00 psf)

Product Tested By: Testing Evaluation Laboratories, Inc.  
Report No: TEL 01461721  
Expiration Date: **June 30, 2024**

Administrator's Signature: \_\_\_\_\_  


**NATIONAL ACCREDITATION AND  
MANAGEMENT INSTITUTE, INC.**  
4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
Fax: (804) 684-5122