

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI014886.19
DATE: 07/13/2020
CERTIFICATION PROGRAM: Structural
COMPANY: Reeb
CODE: 847-1

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Reeb Millwork Corporation 1000 Maloney Circle Bethlehem, PA 18015	Series "Smooth-Star" Opaque Fiberglass Out-Swing Side Hinged Door (w/Composite Jambs) Configuration: OXO Glazing: IG-1/8" Tempered Glass/1/8" Annealed Glass/0.090" Saflex PVB Interlayer/1/8" Annealed Glass Frame: W-2845mm(112") H-2470mm(97.25") Panel: W-914mm(36") H-2419mm(95.25") DLO: W-527mm(20.75") H-2000mm(78.75")

SPECIFICATION	PRODUCT RATING
ASTM E283-04/E330-02/E331-00 ASTM E1886-13a/E1996-14a	Design Pressure: +50 /-50 psf Water Penetration Resistance Test Pressure: 0 Pa (0.0 psf) Wind Zone 4 - Missile Level D

Product Tested By: Testing Evaluation Laboratories, Inc.
Report No: TEL 01462466
Expiration Date: **July 31, 2024**

Administrator's Signature:  _____

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122