

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI014890
DATE: 06/26/2020
CERTIFICATION PROGRAM: Fire
COMPANY: Trinity Glass
CODE: 594-1
EXPIRATION DATE: 06/24/2024

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Trinity Glass International, Inc. 33615 1 st Way S Federal Way, WA 98003	Endura 20 Minute Category C Proprietary Wood Door Frames Manufacture Specific Fire Door Frames for Single Swing Only Installation in 20 Minute Locations Single Door Maximum Size: 3'0" x 8'0" Minimum Thickness: 4-9/16"

SPECIFICATION	PRODUCT RATING
NFPA 252 (1995) UL 10b (1997)(2009) CAN/ULC S104 (1980)(2010) UBC Standard 7-2 (1994)	20 Minute-With Hose Stream Neutral Pressure Category C- Proprietary Frame

TEST REPORT
Intertek Test Report No(s): J98027188-231

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be "Shi D", written over a horizontal line.

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122