

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI014903.02
DATE: 07/14/2020
CERTIFICATION PROGRAM: Structural
COMPANY: American Openings
CODE: 1348-1

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
American Openings, Inc. 6885 E. Southpointe Road Tucson, AZ 85734	Series "A-210" Aluminum Single Hung Window Configuration: O/X Glazing: Insulating Glass (Annealed) Frame: W-1118mm(41.25") H-1505mm(59.25") Sash: W-1000mm(39.38") H-772mm(30.38") DLO: W-956mm(37.63") H-676mm(26.63")

SPECIFICATION	PRODUCT RATING
ASTM E330-14	Design Pressure: ±1680 Pa (35 psf)

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-110-23347-2
Expiration Date: **May 31, 2024**

Administrator's Signature:  _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122