

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI014903
DATE: 07/14/2020
CERTIFICATION PROGRAM: Structural
COMPANY: American Openings
CODE: 1348-1

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
American Openings, Inc. 6885 E. Southpointe Road Tucson, AZ 85734	Series "A-210" Aluminum Single Hung Window Configuration: O/X Glazing: Insulating Glass (Annealed) Frame: W-1200mm(47.25") H-1810mm(71.25") Sash: W-1153mm(45.38") H-914mm(36") DLO: W-1105mm(43.5") H-826mm(32.5")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17	Class R-PG25 1194 x 1803 (47 x 71)-H Design Pressure: ±1200 Pa (25 psf) Water Penetration Resistance Pressure: 260 Pa (5.43 psf)

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-110-23346-1
Expiration Date: **May 31, 2024**

Administrator's Signature: _____


NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Fax: (804) 684-5122