

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI014904.02  
DATE: 07/14/2020  
CERTIFICATION PROGRAM: Structural  
COMPANY: American Openings  
CODE: 1348-1

To verify that the "Notice of Product Certification" is valid, please visit [www.NAMICertification.com](http://www.NAMICertification.com) to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>American Openings, Inc.</b> <b>6885 E. Southpointe Road</b> <b>Tucson, AZ 85734</b>	<b>Series "A-220/230"</b> <b>Aluminum Horizontal Sliding Window</b>  Configuration: XOX Glazing: Insulating Glass (Annealed)  Frame: W-2426mm(95.5") H-1810mm(71.25") Panel: W-591mm(23.25") H-1765mm(69.5") DLO: W-1140mm(44.88") H-1689mm(66.5")

SPECIFICATION	PRODUCT RATING
<b>ASTM E330-14</b>	<b>Design Pressure: ±1200 Pa (25 psf)</b>

Product Tested By: National Certified Testing Laboratories  
Report No: NCTL-110-23348-2  
Expiration Date: May 31, 2024

Administrator's Signature: \_\_\_\_\_

A handwritten signature in black ink, appearing to be 'S. D.', written over a horizontal line.

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
Fax: (804) 684-5122