NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO:
DATE:
CERTIFICATION PROGRAM:
COMPANY:
CODE:

NI014904
07/14/2020
Structural
American Openings
1348-1

To verify that the "Notice of Product Certification" is valid, please visit <u>www.NAMICertification.com</u> to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

	PRODUCT DESC	RIPTION
Series "A-220/230"		
Aluminum Horizontal Sliding Window		
	Configuration: Glazing: Insulating Gla	
Frame:	W-2426mm(95.5")	H-1810mm(71.25")
Panel:	W-591mm(23.25")	H-1765mm(69.5")
DLO:	W-1140mm(44.88")	H-1689mm(66.5")
	Frame: Panel:	Series "A-220 Aluminum Horizontal S Configuration: : Glazing: Insulating Gla: Frame: W-2426mm(95.5") Panel: W-591mm(23.25")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17	Class R-PG25 2438 x 1803 (96 x 71)-HS Design Pressure: ±1200 Pa (25 psf) Water Penetration Resistance Pressure: 180 Pa (3.76 psf)

Product Tested By: Report No: Expiration Date: National Certified Testing Laboratories NCTL-110-23348-1 May 31, 2024

Sh

Administrator's Signature:

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway Hayes, VA 23072 Tel: (804) 684-5124 Fax: (804) 684-5122