

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI014915-R1
DATE: 07/23/2020
CERTIFICATION PROGRAM: Fire
COMPANY: Trinity Glass
CODE: 594-1
REVISION DATE: 07/30/2020
EXPIRATION DATE: 07/31/2024

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

| COMPANY NAME AND ADDRESS | PRODUCT DESCRIPTION |
|---|--|
| Trinity Glass International, Inc. 33615 1st Way S Federal Way, WA 98003 | Series "44mm SMC" Side-Hinged Door Assembly (w/Intumescent Foam Core) Manufacturer Specific Fire Doors for Single Swing Installation in 20 Minute Locations 1/2" Minimum Latch Throw Single Swing Only Single Door Maximum Size: 3'0" x 6'8" Minimum Thickness: 1.73" |

| SPECIFICATION | PRODUCT RATING |
|--|--|
| NFPA 252 (1995) UL 10c (1998) UL 10b (1998) UBC Standard 7-2 (1997) | 20 Minute - Positive Pressure With Hose Stream Category B Door-Additional Edge Seal Required For Use in Category C Frame (or may also be installed in Category C-Proprietary in accordance with individual manufacturer's listing) |

| TEST REPORT |
|--|
| Underwriters Laboratory Test Report No(s): R25197 |

Administrator's Signature: 

NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.
 4794 George Washington Memorial Highway
 Hayes, VA 23072
 Tel: (804) 684-5124/Fax: (804) 684-5122