

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI014922.01
DATE: 07/29/2020
CERTIFICATION PROGRAM: Structural
COMPANY: Prime Window
CODE: 2287-1

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Prime Window Systems 12775 East 38th Avenue Denver, CO 80239	Series "4500" Glazed Vinyl Out-Swing North American Frame Side-Hinged Door Configuration: X Glazing: Insulating Glass (Tempered) Frame: W-914mm(36") H-2108mm(83") Panel: W-838mm(33") H-2051mm(80.75") DLO: W-610mm(24") H-1822mm(71.75")

8

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11	Class LC-PG80 914 x 2108 (36 x 83)-SHD Design Pressure: ±3840 Pa (±80 psf) Water Penetration Resistance Test Pressure: 580 Pa (12.11 psf)

Product Tested By: Architectural Testing, Inc.
Report No: D2429.08-109-47
Expiration Date: **June 30,2024**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122