NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI014936

DATE: 08/20/2020

CERTIFICATION PROGRAM:

PROGRAM: <u>Fire</u>
COMPANY: <u>BMC Millwork</u>

CODE: 1665-1

EXPIRATION DATE: 08/31/2024

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
BMC Millwork Corporation	Steve's & Sons/Crest Doors
399 Northpoint Parkway	6-Panel Embossed Steel Fire Door
Acworth, GA 30102	Manufacturer Specific Fire Doors for Single Swing Installation in 20 Minute Locations
	1/2" Minimum Latch Throw Single Swing Only
	Single Maximum Size: 3'0" x 6'8" Minimum Thickness: 1-3/4"

SPECIFICATION	PRODUCT RATING
ASTM E152-81a	20 Minute-Neutral Pressure
UL 10B (1997)(2009)	Without Hose Stream
NFPA 252 (1999)	Category A - No Additional Edge Sealing
	System Required

TEST REPORT	
Intertek Test Report No: 3125633	

Administrator's Signature:

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway Hayes, VA 23072 Tel: (804) 684-5124

Fax: (804) 684-5122