

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI014943
DATE: 08/24/2020
CERTIFICATION PROGRAM: Fire
COMPANY: Carter Lumber
CODE: 2674-1
EXPIRATION DATE: 08/31/2024

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Carter Lumber Corporation 2601 Westinghouse Boulevard Charlotte, NC 28273	Jeld Wen Premium 20 Minute Neutral Pressure Fiberglass Side-Hinged Door Assemblies Manufacturer Specific Fire Doors for Single Swing Installation in 20 Minute Locations 1/2" Minimum Latch Throw Single Swing and Pairs Allowed Single Swing Maximum Size: 3'0" x 8'0" Minimum Thickness: 1-3/4" Pairs Maximum Size: 6'0" x 6'8" Minimum Thickness: 1-3/4"

SPECIFICATION	PRODUCT RATING
NFPA 252 (2008) UL 10B (2008/2009) CAN/ULC S104 (2010)	20 Minute-Neutral Pressure With Hose Stream Category B - Additional Edge Sealing Required

TEST REPORT
Intertek Test Report No: 3091617, 3145981MID-005b, 3153159MID-007, 100211525COQ-001

Administrator's Signature: 

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122