

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI014944  
DATE: 08/24/2020  
CERTIFICATION PROGRAM: Fire  
COMPANY: Carter Lumber  
CODE: 2674-1  
EXPIRATION DATE: 08/31/2024

To verify that the "Notice of Product Certification" is valid, please visit [www.NAMICertification.com](http://www.NAMICertification.com) to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Carter Lumber Corporation</b> <b>2601 Westinghouse Boulevard</b> <b>Charlotte, NC 28273</b>	<b>Jeld Wen 20 Minute Neutral</b> <b>Pressure Steel Side-Hinged Door</b> <b>Assembly</b>  Manufacturer Specific Fire Doors for Single Swing Installation in 20 Minute Locations  1/2" Minimum Latch Throw Single Swing Only  <b>Single Swing Maximum Size: 3'6" x 6'8"</b> <b>Minimum Thickness: 1-3/4"</b>

SPECIFICATION	PRODUCT RATING
<b>NFPA 252 (2008)</b> <b>UL 10B (2009)</b> <b>UBC 7-2 (1994)</b>	<b>20 Minute-Neutral Pressure</b> <b>Without Hose Stream</b> <b>Category B - Additional Edge Sealing</b> <b>Required</b>

TEST REPORT
<b>Intertek Test Report No: WHI 495-0897, 100108677COQ-001, 100211525COQ-001, 100237214MID-001, 100754937MID-001</b>

A handwritten signature in black ink, appearing to be 'S. M.', written over a horizontal line.

Administrator's Signature: \_\_\_\_\_

**NATIONAL ACCREDITATION AND  
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Fax: (804) 684-5122