

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI013870-R1  
**DATE:** 03/23/2017  
**CERTIFICATION PROGRAM:** Fire  
**COMPANY:** ProVia  
**CODE:** 1212-1  
**REVISION DATE:** 09/16/2020  
**EXPIRATION DATE:** 10/31/2025

To verify that the "Notice of Product Certification" is valid, please visit [www.NAMICertification.com](http://www.NAMICertification.com) to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>ProVia, LLC</b> <b>2150 State Route 39</b> <b>Sugarcreek, OH 44681</b>	<b>20 Minute Category C</b> <b>Proprietary Wood Door Frames</b>  Manufacture Specific Fire Door Frames for Double Swing Installation in 20 Minute Locations  <b>Single Door Maximum Size: 8'0" x 9'0"</b>  <b>Minimum Jamb Depth: 3.5"</b>

SPECIFICATION	PRODUCT RATING
<b>NFPA 252 (2012)</b> <b>UL 10b (1997)</b> <b>UL 10c (2009)</b> <b>CAN/ULC S104 (2010)</b> <b>UBC Standard 7-2 (1994)</b>	<b>20 Minute-With Hose Stream</b> <b>Positive Pressure</b> <b>Category C- Proprietary Frame</b>

TEST REPORT
<b>Intertek Test Report No(s): 101305789COQ-002, 101664134COQ-002</b> <b>Intertek Engineering Evaluation No(s): 102343380MID-001</b>

Administrator's Signature: \_\_\_\_\_

A handwritten signature in black ink, appearing to be 'S. D.', is written over the signature line.

**NATIONAL ACCREDITATION AND  
MANAGEMENT INSTITUTE, INC.**  
4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124/ Fax: (804) 684-5122