

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI014327.01-R1  
DATE: 03/27/2019  
CERTIFICATION PROGRAM: Structural  
COMPANY: Window Crafts  
CODE: 690-1  
REVISION DATE: 09/30/2020

To verify that the "Notice of Product Certification" is valid, please visit [www.NAMICertification.com](http://www.NAMICertification.com) to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Window Craftsmen</b> <b>6031 Clark Center Avenue</b> <b>Sarasota, FL 34238</b>	<b>Series "CM200"</b> <b>Vinyl Casement Window</b> <b>(New Construction or Replacement)</b>  Configuration: X Glazing: Insulated Glass (Annealed)  Frame: W-914mm(36") H-1829mm(72") Vent: W-865mm(34.06") H-1780mm(70.06") DLO: W-752mm(29.63") H-1667mm(65.63")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-11</b> <b>AAMA/WDMA/CSA 101/I.S.2/A440-08</b> <b>CSA A440S1-09</b>	<b>Class LC-PG60 914 x 1829 (36 x 72)-C</b> <b>Design Pressure: ±2880 Pa (60 psf)</b> Water Penetration Resistance Test Pressure: 440 Pa (9.2 psf) <b>Canadian Air Infiltration/Exfiltration Level: A3</b>

Product Tested By: Intertek, PLC  
Report No: I3879.03-501-44/I3879.01-501-47/W-1893  
Expiration Date: **July 31, 2026**

A handwritten signature in black ink, appearing to be 'S. D.', written over a horizontal line.

Administrator's Signature: \_\_\_\_\_

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
Fax: (804) 684-5122