NOTICE OF PRODUCT CERTIFICATION '



CERTIFICATION NO: NI014966.01

DATE: 09/08/2020

CERTIFICATION PROGRAM: Structural

COMPANY: Origin

CODE: <u>1985-1</u>

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status.

Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Origin USA, Inc.	Series "OS44" Aluminum
573 Paul Morris Drive	Sliding Glass Door
Englewood, FL 34223	
	Configuration: OXXO Glazing: Insulating Glass (Tempered)
	Frame: W-6198mm(244") H-3048mm(120")
	Panel: W-1525mm(60") H-2968mm(116.88")
	DLO: W-1416mm(55.75") H-2801mm(110.25")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17	Class R-PG15 6198 x 3048 (244 x 120)-SD Design Pressure: ±720 Pa (±15 psf) Water Penetration Resistance Test Pressure: 140 Pa(2.92 psf)

Product Tested By: Intertek - West Palm Beach, FL

Report No: K1037.01-450-44 Expiration Date: **June 30, 2024**

Administrator's Signature:

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway Hayes, VA 23072 Tel: (804) 684-5124

Fax: (804) 684-5122