

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI014966
DATE: 09/08/2020
CERTIFICATION PROGRAM: Structural
COMPANY: Origin
CODE: 1985-1

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

| COMPANY NAME AND ADDRESS | PRODUCT DESCRIPTION |
|---|---|
| Origin USA, Inc. 573 Paul Morris Drive Englewood, FL 34223 | Series "OS44" Aluminum Sliding Glass Door Configuration: XXX Glazing: Insulating Glass (Tempered) Frame: W-4613mm(182") H-3048mm(120") Panel: W-1549mm(61") H-2968mm(116.88") DLO: W-1416mm(55.75") H-2801mm(110.25") |

| SPECIFICATION | PRODUCT RATING |
|--|--|
| AAMA/WDMA/CSA 101/I.S.2/A440-17 | Class R-PG15 4613 x 3048 (182 x 120)-SD Design Pressure: ± 720 Pa (± 15 psf) Water Penetration Resistance Test Pressure: 140 Pa(2.92 psf) |

Product Tested By: Intertek - West Palm Beach, FL
Report No: K1037.01-450-44
Expiration Date: June 30, 2024

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be "MD", is written over the signature line.

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122