

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI014979.01  
DATE: 09/21/2020  
CERTIFICATION PROGRAM: Structural  
COMPANY: Survivalite  
CODE: 1872-1

To verify that the "Notice of Product Certification" is valid, please visit [www.NAMICertification.com](http://www.NAMICertification.com) to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Survivalite Impact Window Systems, LLC</b> <b>1385 Morningside Drive</b> <b>Mount Dora, FL 32757</b>	<b>Series "Outdoor Tornado Door System"</b> <b>Outswing Aluminum</b> <b>Side-Hinged Door Assembly</b> <b>(Tornado Only)</b>  Configuration: X Glazing: IG-1/4" Tempered Glas/0.025"Clear Film Interlayer/1/4" Polycarbonate/0.025"Clear Film Interlayer/1/8" Polycarbonate/0.025"Clear Film Interlayer/1/8" Polycarbonate  Frame: W-1003mm(39.5") H-2184mm(86") DLO: W-675mm(26.56") H-1757mm(69.19")

SPECIFICATION	PRODUCT RATING
<b>ICC 500-14</b> <b>ASTM E330-02/E283-04/E331-00</b>	<b>Passed</b> <b>Design Pressure: +250/-250 psf</b> Water Penetration Resistance Test Pressure: 1796 Pa (37.5 psf)

Product Tested By: Blackwater Testing, Inc.  
Report No: BT-SIS-20-001  
Expiration Date: August 31, 2024

Administrator's Signature: \_\_\_\_\_

**NATIONAL ACCREDITATION &  
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
Fax: (804) 684-5122