

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI014979
DATE: 09/21/2020
CERTIFICATION PROGRAM: Structural
COMPANY: Survivalite
CODE: 1872-1

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Survivalite Impact Window Systems, LLC 1385 Morningside Drive Mount Dora, FL 32757	Series "Outdoor Tornado Door System" Outswing Aluminum Side-Hinged Double Door Assembly (Tornado Only) Configuration: XX Glazing: IG-1/4" Tempered Glas/0.025"Clear Film Interlayer/1/4" Polycarbonate/0.025"Clear Film Interlayer/1/8" Polycarbonate/0.025"Clear Film Interlayer/1/8" Polycarbonate Frame: W-2527mm(99.5") H-2489mm(98") DLO: W-978mm(38.5") H-2062mm(81.19")

SPECIFICATION	PRODUCT RATING
ICC 500-14 ASTM E330-02/E283-04/E331-00	Passed Design Pressure: +250/-250 psf Water Penetration Resistance Test Pressure: 1796 Pa (37.5 psf)

Product Tested By: Blackwater Testing, Inc.
Report No: BT-SIS-20-001
Expiration Date: August 31, 2024

Administrator's Signature: _____

**NATIONAL ACCREDITATION &
MANAGEMENT INSTITUTE, INC.**
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122